



11/11/2025

The Renaissance Charter School 2
45-20 83rd Street
Elmhurst, NY 11373
Attn: Samuel Gauthier

JOB NUMBER: 25-02410

CLIENT REFERENCE: Lead in Water

JOB ADDRESS: 45-20 83rd Street, Elmhurst, NY 11373

We are pleased to present you with a TESTOR close-out document for environmental services at the location address listed above.

LEAD IN WATER:

TESTOR (Testor Technology Environmental Services, Inc.) conducted a lead inspection and sampling at the above referenced site on November 4th, 2025. Twenty (20) lead in water samples were collected by our technician, Y. Lalic, as directed, and transported by chain of custody to KAM Consultants using EPA Method 200.9 for analysis. The EPA Regulatory Limit is level is 15.00 µg/L.

Please see below for results:

Location	Draw	Result µg/L
1 st Floor – Fountain (Left from Entrance)	1 st	<1.0
	2 nd	<1.0
1 st Floor – Fountain (Right from Elevator)	1 st	<1.0
	2 nd	<1.0
1 st Floor – Fountain (Left from Elevator)	1 st	<1.0
	2 nd	<1.0
Kitchen Faucet	1 st	<1.0
	2 nd	<1.0
4 th Floor – Fountain (Gym)	1 st	<1.0
	2 nd	<1.0
3 rd Floor – Fountain (Left from Elevator)	1 st	<1.0
	2 nd	<1.0
3 rd Floor – Fountain (Right from Elevator)	1 st	<1.0
	2 nd	<1.0
2 nd Floor – Fountain (Left from Elevator)	1 st	<1.0
	2 nd	<1.0
2 nd Floor – Fountain (Right from Elevator)	1 st	<1.0
	2 nd	<1.0
2 nd Floor – Fountain (3 rd Fountain)	1 st	<1.0
	2 nd	<1.0

All results are below the EPA Regulatory Limit.

Please refer to the attached report. Please be aware that payment is required at service completion and very much appreciated.

Thank you for your business.

Sincerely,

Sten Evenhouse
President, TESTOR
contact@testortech.com

Confidentiality Notice: This report relates only to the samples tested and shall not be reproduced without the written consent of the originating laboratory. Unless otherwise indicated, the information contained in this communication is confidential and is solely for the use of the sender's intended recipient(s). Any use of this report other than the intended use of providing analytical data is prohibited. If you have received this report in error, please notify the sender immediately by phone or email.